

**Model: PDG300S** 

# 300 KVA / 3 - Phase



Powercity generators are designed in conformance with European Standards certified by independent certifying agency the Materials Industrial Research and Technology Center (MIRTEC) with certificate number MC/TH-C-269/08. The principles in design, safety, rating and performance are in accordance with European Standards EN 12601:2001, EN 60204-1:2006, EN 60034-1:2004, EN ISO 12100-1:2003 and EN ISO 12100-2:2003. Generators are designed and built to provide electrical power for stand-by or continuous use. Comes with 2 years or 2,000 run hours limited warranty whichever comes first.

#### **Features:**

- MANUAL or AUTOMATIC starting and stopping capability.
- Digital controller.
- Direct injection diesel engine for fuel efficiency.
- Brushless rotating field generator with class H insulation.
- NEMA 3R enclosure suitable for outdoor use.
- Integral vibration isolators.
- Silent type generator.

# **Specifications**

Model	PDG300S		
Alternator			
Make & Model Powercity SLG-444D			
Frequency	Hz	50	60
Output Rating	Prime	250	300
(KVA)	Standby	275	330
Phase	3	-Phase (4 Wires)	
Rated Voltage	V	200-240 / 380-440	
Power Factor		0.8 (Lagging)	
Voltage	0/		
Regulation	%	Within +/- 1.5	
Excitation		Brushless rotating exciter	
		with Automatic Voltage	
		Regulator (AVR)	
Insulation		Class H	
Engine			
Make & Model		CUMMINS	
		NTA855-G1	
Туре		Vertical inline; water	
		cooled; 4 stroke; direct	
		injected; turbo- intercooled	
Output Rating	Kw/rpm	240/1500	287/1800
No. of cylinders-	mm	6 – 140 X 152	
Bore X Stroke		0 1.37.132	
Piston	L	14	
Displacement		ACT: 44	
Fuel		ASTM No. 2 Diesel	
Fuel	. //	45.0	F.C. 4
Consumption @	L/h	45.2	56.1
75% Load			
Lube Oil	L	38.6	
Capacity Coolant			
	L	60.6	
Capacity  Battery Capacity	V-Ah	12V-150Ah (2 pcs)	
Battery Capacity Fuel Tank	v-An	12v-150An (2 pcs)	
Capacity	L	400	
Unit			
Length mm 4200			
Dimensions	Width mm	1400	
	Height mm	1900	
Dry Weight	Kg	3100	
Sound Level			
dB @ 7 m	Journa L	72	78
45 @ 7 111		12	, 0

Note: Due to continuous product improvement, the generator set manufacturer reserves the right to change the design or specifications without notice and without any obligation or liability whatsoever.

# **Engine:**



# **G-Drive** Generator Engines

Diesel engines with unrivalled reputation for reliability in generator industry!

### Standards:

EN 12601:2001 – Reciprocating internal combustion engine driven generating sets – Safety.

EN 60204-1:2006 – Safety of machinery; electrical equipment of machines – General requirements.

EN 60034-1:2004 – Rotating electrical machines – Rating and performance.

EN ISO 12100-1:2003 – Safety of machinery; basic concepts and general principles for design Part 1.

EN ISO 12100-2:2003 – Safety of machinery; basic concepts and general principles for design Part 2.

Applicable EGSA\* Standards.

\*- Electrical Generating Systems Association

# **Application Notes:**

STANDBY RATING: Standby ratings apply to installations served by a reliable utility source. This rating is applicable to varying loads for the duration of a power outage. There is no overload capability for this rating. Ratings are in accordance with ISO 3046-1, BS 5514, AS 2789 and DIN 6271.

PRIME POWER RATING: Prime power ratings apply to installations where utility power is unavailable or unreliable. At varying load the number of generator set operating hours is unlimited. A 10% overload capacity is available for one hour in twelve hours. Ratings in accordance with ISO 8528-1, overload power in accordance with ISO 3046-1, BS 5514, AS 2789, and DIN 6271.

#### **GENERAL GUIDELINES FOR DERATION:**


Altitude: Derate 0.5% per 100 meter (328 ft.) elevation above 1000 meter (3279 ft.).

Temperature: Derate 1.0% per 10°C (18°F) temperature above 40°C (104°F).

FUEL: Use clean diesel fuel only. Diesel fuel quality should meet the specifications of ASTM D975 and the Worldwide Fuel Charter.

SOUND LEVEL: Sound level is measured in free field environment (acoustic test chamber) where sound may propagate free from any form of obstruction.

#### dB Range:



# Quality Assurance:







ISO 9001:2008 Certificate No. U13Q2GZ682452F1M

Manufactured by:

**Powercity Electromechanical & Equipment Co Ltd** Fujian, China

Distributed in the Philippines by:

## **Powercity Corporation**

Km. 20, East Service Road, Muntinlupa City Metro Manila, Philippines Tel. (+632) 869 1991, (+632) 8697520

Fax. (+632) 8693869

Email: contactus@powercity.ph

Made in China